

## What's New?

This release of RF500A (Issue M5) brings new enhancements and functionality to the already industry leading RF500 system.

Take a look at what's new below and explore the system yourself.



For further information and details of these new features please consult the web view help file.


## Audit Trail Filtering

The Audit Trail now has advanced filtering options allowing the user to refine the vast wealth of information it provides.

Time	Action	User	Comments
27 Mar 2013 12:25	Login	paul m	
27 Mar 2013 12:19	System Call	System	CSV data export started
27 Mar 2013 12:18	System Call	System	Gateway switch on. (0)
27 Mar 2013 12:16	System Call	System	System Update
27 Mar 2013 12:11	Login	comark	
27 Mar 2013 11:59	System Call	System	CSV data export started
27 Mar 2013 11:58	System Call	System	Gateway switch on. (0)
27 Mar 2013 11:56	System Call	System	System Update
27 Mar 2013 11:52	System Call	System	CSV data export started
27 Mar 2013 11:52	Login	vwtreasure	
27 Mar 2013 11:51	Login	comark	
27 Mar 2013 11:51	System Call	System	Gateway switch on. (0)
27 Mar 2013 11:48	System Call	System	System Update

## Repeat Alarms

RF500A now has the ability to send Repeat Alarm notifications if the user desires, this can be a complex feature but the basic concept is illustrated below (there is an FAQ section for this feature at the end of this document).



## Alarm View

A new Alarm View page has been added to allow instantaneous access to current and ongoing transmitter alarm events.

### Active Alarm List 17:06 Mar 26 2013

Back		Refresh								
Tx Serial No.	Location	Description	Alarm Acknowledged	Alarm Snoozed	Repeat Alarm Period	Ch.	In Alarm	Ch Name	Next Repeat	
<a href="#">BA04060016</a>	location 2	window	Yes	No	5 Minutes	<a href="#">Ack / Snooze</a>	Int	Yes	temp	26 Mar 2013 17:09
<a href="#">BA04060034</a>	location 1	desk	No	Yes	15 Minutes	<a href="#">Ack / Snooze</a>	Int	No	desk	26 Mar 2013 17:21
<a href="#">CE04090003</a>	location 1	CE04090003	Yes	No	Not Set	<a href="#">Ack / Snooze</a>	Int	Yes	int ch	
<a href="#">CC10100030</a>	location 1	CC10100030	No	No	Not Set	<a href="#">Ack / Snooze</a>				
<a href="#">CC10100060</a>	location 1	CC10100060	No	No	15 Minutes	<a href="#">Ack / Snooze</a>	Ext1	Yes	test rh	26 Mar 2013 17:09
							Ext2	No	test temp	26 Mar 2013 17:09
<a href="#">CA11070401</a>	location 1	cabinet 56	Yes	No	Not Set	<a href="#">Ack / Snooze</a>	Int	Yes	amb	
							Ext1	Yes	Ext 1ch	
							Door	Yes	door	

## Home Screen Enhancements

This has been further refined to reflect the new Repeat Alarms enhancement, a new colour code for Alarms has been used to provide a clear indication of the current alarm status with just a quick glance. Additionally access to the Alarm View page via the notification area is available during alarm events.



**COMARK**

**1 Tx with unacknowledged alarms / 1 Tx in Alarm**

**Repeat 1**

**12:54 Mar 27 2013.**


**Warning Filter On**

Refresh Administration My Preferences Logout Multi-Graph Map

Data for today System Manual Webview Help RF515 Guide Whats New


No Signal	In Alarm	Unack. Alarm	Snoozed	Power Fault	Low Battery	Sensor Fault	Command
Repeat Alm Test							
CA07060279	27 Mar 12:53	Int	Internal	24.0	19.7	24.0	20.9 °C
31) Pauls Location		Ext1	External	69.8	19.7	73.4	21.0 °C
Repeat Alm Test							

0.0



## Relay Output Toggle

This option now gives the ability for the relay outputs to momentarily activate (for a duration of 3 seconds) and then return to their previous state. This provides transient activations to allow multiple triggers for edge triggered devices (for example Auto-diallers).



The image shows a web interface for a COMARK device. At the top left is the COMARK logo. The main title is "Hardware Status". Below the title is a navigation bar with buttons for "Back", "Refresh", and "Save". To the right of the navigation bar is a "Password Required" field with five dots. The main content area displays various system parameters in a table-like format. At the bottom, there are two buttons: "Shutdown Gateway" and "Reset Gateway". Below these buttons is a section titled "On hardware event Email:" followed by a grid of 12 checkboxes, numbered 1) through 12).

COMARK	
RF500A	Serial No. 03110003 / Software M5-B32 / Firmware 1.00 : RF 2.00R / Data ID 51924
Radio Address	0080400044800483
Power Mode	External Power Applied
Battery Status	8.1V 39.7C
Charging Status	Trickle charge mode Fully Charged
Power Input	Ext 12V not connected POE 11.7V
System	PC=5.0V, micro=3.3V, pwr line=11.0V, case=36C por=0-wtd=0-jtag=0-bor=0-extr=0-on=19
Internal Backup	Last file 11 of 11 sent Wed Mar 27 16:22:16 2013
Data Packets	ram RF 0 : ram NW 0 : sd 0
Clocks	PC 27 Mar 2013 16:23 / Micro =27 Mar 2013 16:23 d=0
Switch output 1	output normally open <input checked="" type="radio"/> close <input type="radio"/> <input checked="" type="checkbox"/> Toggle mode
Switch output 2	output normally open <input checked="" type="radio"/> close <input type="radio"/> <input checked="" type="checkbox"/> Toggle mode
Memory Status	Master SD 19%, Backup SD 19%, Ram 18%

Shutdown Gateway      Reset Gateway

On hardware event Email:

<input type="checkbox"/> 1)	<input type="checkbox"/> 2)	<input type="checkbox"/> 3)
<input type="checkbox"/> 4)	<input type="checkbox"/> 5)	<input type="checkbox"/> 6)
<input type="checkbox"/> 7)	<input type="checkbox"/> 8)	<input type="checkbox"/> 9)
<input type="checkbox"/> 10)	<input type="checkbox"/> 11)	<input type="checkbox"/> 12)

## Repeat Alarms FAQ

### 1. What are RF500A Repeat Alarms?

Each Transmitter can be set with a repeat alarm time, e.g. 1 Hour. If the transmitter goes into alarm e-mails and warnings will be sent from the Gateway. For the duration of the alarm event if you acknowledge/snooze it the repeats will continue at the pre-set time until the alarm either clears itself, or you set Repeat Time Off.

### 2. Should I upgrade?

Upgrades for RF500A are available free of charge from Comark, however there are some important questions to answer before deciding to upgrade.

1. Is the Gateway validated to a standard such as 21 CFR Part 11? If yes, then the advice from Comark is only to upgrade if you are planning to validate the system again.
2. My system is not validated and I really want repeat alarms. Then our advice is go ahead and upgrade your system in the normal way. If you need help with this process please contact our Technical Department.

### 3. Can I snooze an alarm to be dealt with later?

Yes the function to acknowledge an alarm has been expanded to include 'snooze'.

### 4. How do I stop repeat alarms?

When acknowledging an alarm you can set RF500 to Repeat Time Off. This means that if acknowledging the alarm you will not get another repeat. If snoozing you will also not get another repeat alarm, you will however have the opportunity to acknowledge the alarm in the future.

### 5. What happens if I ignore an alarm?

If you ignore an alarm it will continue to be repeated at the Default Repeat Alarm Period set in the properties for the transmitter.

### 6. What happens if the alarm goes away on its own before I acknowledge it?

Nothing, you still have the opportunity to acknowledge the alarm. Just remember that if another alarm comes in for the same channel/transmitter you are always acknowledging global alarms for the transmitter.

### 7. How do I set the Default Repeat Alarms Period?

The Default Repeat Alarm Period is set in the transmitter properties page. This can be accessed from the serial number link at the top right of the Transmitter Summary page, or from the Transmitters page accessed from the Administration Section.

### 8. How long can I set the repeat alarm for?

The repeat alarm can be set for between 5 mins to a maximum of 8 days, in a number of pre-defined steps on the Gateway.

### 9. Can I set cascading alarms?

This release does not include cascading alarms.

### 10. How do I view active alarm events?

From the Home page when an Alarm is active a new link will appear. Click on this link to view the new Alarm events page. This page is only active when an alarm is active on the Gateway or an alarm has not been acknowledged.

### 11. Can I add a comment when snoozing an alarm?

Yes, this is mandatory. All Snoozing or Acknowledging of alarms must be completed with a short comment. Minimum length is 1 character and the comment cannot be more than 100 characters.

### 12. Can I snooze/acknowledge alarms multiple times?

Yes, if the alarm is still active then it can be snoozed, or acknowledged, multiple times. If the alarm has cleared itself, you can still add multiple comments if the size of the box is not enough, by first snoozing the alarm and then following that up with the acknowledge or another snooze.

**13. Do I have to wait for the snooze time to end to acknowledge the alarm?**

No, you can set another snooze period or acknowledge the alarm at any time while it is active.

**14. Is Alarm Acknowledge per channel?**

No, alarm Acknowledge is per transmitter not per individual channel.

**15. How do I clear an alarm from the Gateway Home Page?**

Clearing an alarm can only be achieved by the event that caused the alarm returning to a condition within the alarm limits. Even if an alarm has been acknowledged it will stay on the Alarm events page for as long as it is active.

**16. What has happened to 'No Data' and 'Tasking' Icons from the Home Page?**

In order to make room for the new annunciators 'In Alarm' and 'Snoozed', we have removed 'Tasking' and 'No Data'. This information does still appear in the notifications box, e.g. qT and No Data in red text under the description for each of the transmitters, and in the hover text for each transmitter, so the information is still readily available.

**17. Do repeat alarms work on a per channel basis on each transmitter?**

Yes, repeat alarms works on a per channel basis.

**18. What happens if a new alarm comes in on a transmitter with a snoozed alarm?**

Fresh e-mails and alerts will be sent out for the channel in alarm.

**19. If I Upgrade do I get repeat alarms immediately?**

No. By default for an upgrade to RF500A we set the default repeat alarm to be off, giving you the choice to set repeat alarms for individual transmitters.

**20. Can I upgrade my RF500, or RF500LITE, Gateway for repeat Alarms?**

No sorry this upgrade is only suitable for RF500A Gateways.